

Wabbaseka Waterworks

2025 Annual Drinking Water Quality Report

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand, and be involved in, the efforts we make to continually improve the water treatment process and protect our water resources.

Where Does Our Drinking Water Come From?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our source of water is one well that pumps from the Sparta Sand Aquifer.

How Safe Is The Source Of Our Drinking Water?

The Arkansas Department of Health has completed a Source Water Vulnerability Assessment for Wabbaseka Waterworks. The assessment summarizes the potential for contamination of our source of drinking water and can be used as a basis for developing a source water protection plan. Based on the various criteria of the assessment, our water source has been determined to have a low susceptibility to contamination. You may request a summary of the Source Water Vulnerability Assessment from our office.

What Contaminants Can Be In Our Drinking Water?

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; Pesticides and herbicides which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; Organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure tap water is safe to drink, EPA has regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Am I at Risk?

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from small amounts of contamination. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. In addition, EPA/CDC guidelines on appropriate means to lessen the risk of infection by microbiological contaminants are also available from the Safe Drinking Water Hotline.

Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

How Can I Learn More About Our Drinking Water?

If you have any questions about this report or concerning your water utility, please contact Operator Julian Armstrong, at 870-766-4262. We want our valued customers to be informed about their water utility. If you want to learn more about your water system, please attend any of our monthly meetings held on the second Thursday of each month at 7:00 PM at the convention center, 100 Pawpaw Street.

TEST RESULTS

We routinely monitor for constituents in your drinking water according to Federal and State laws. The test results table shows the results of our monitoring for the period of January 1st to December 31st, 2025. In the table you might find terms and abbreviations you are not familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - unenforceable public health goal; the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA - Not applicable

Parts per billion (ppb) - a unit of measurement for detected levels of contaminants in drinking water. One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) - a unit of measurement for detected levels of contaminants in drinking water. One part per million corresponds to one minute in two years or a single penny in \$10,000.

RTCR - Revised Total Coliform Rule. Regulation effective April 1, 2016.

TEST RESULTS

INORGANIC CONTAMINANTS

Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	Major Sources in Drinking Water
Fluoride	N	0.16	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth

LEAD AND COPPER TAP MONITORING

Contaminants	Number of Tap Samples	Number of Sites over Action Level	90 th Percentile Result	Unit	Action Levels	Major Sources in Drinking Water
Lead	5	1	0.023	ppm	0.015	Corrosion from household plumbing systems; erosion of natural deposits
Copper	5	0	0.321	ppm	1.3	

- ♦ The results above are from our last tap sample monitoring period in 2023. Our next required monitoring period is in 2026.
- ♦ Exposure to lead can cause serious health effects in all age groups. Infants and children who drink water containing lead could have decreases in IQ and attention span and increases in learning and behavior problems. Lead exposure among women who are pregnant increases prenatal risks. Lead exposure among women who later become pregnant has similar risks if lead stored in the mother's bones is released during pregnancy. Recent science suggests that adults who drink water containing lead have increased risks of heart disease, high blood pressure, kidney and nervous system problems.

LEAD SERVICE LINE INFORMATION

- ♦ As part of our ongoing efforts to comply with federal regulations, we have developed a service line inventory to identify potential lead service lines within our system. A copy of the inventory is available from our office upon request.

REGULATED DISINFECTANTS

Disinfectant	Violation Y/N	Level Detected	Unit	MRDLG (Public Health Goal)	MRDL (Allowable Level)	Major Sources in Drinking Water
Chlorine	N	Average: 0.83 Range: 0.3 - 3.4	ppm	4	4	Water additive used to control microbes

BY-PRODUCTS OF DRINKING WATER DISINFECTION

Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)
HAA5 [Haloacetic Acids]	N	2.92	ppb	0	60
TTHM [Total Trihalomethanes]	N	1.76	ppb	NA	80

- ♦ We are on a reduced monitoring schedule and are required to sample only one quarter every 3 years. The results above are from the 2023.

VIOLATIONS - Wabbaseka Waterworks

TYPE: Public Education	FROM:	TO:	CORRECTIVE ACTION:
Failed to provide public notice of a National Primary Drinking Water Regulation Violation regarding failure to submit the proper number of valid bacteriological samples.	04/01/2025	Ongoing	None taken
TYPE: Annual Drinking Water Quality Reporting			
Consumer Confidence Report (CCR) - Failure to adequately distribute annual water quality report to customers	7/1/2025	Ongoing	None taken

SIGNIFICANT DEFICIENCY

Under the federal Safe Drinking Water Act, each Water Treatment System must be surveyed (audited) by the Arkansas Department of Health, and all uncorrected Significant Deficiencies must be identified, corrected, and reported to the public. The following was reported on May 7, 2025, upon inspection.

Nature of Deficiencies	Progress to Date
The elevated storage tank's vent must be fitted with a 24-mesh screen to prevent contaminants from entering the tank.	No progress report received.